



Certificate number: 2506710 (1)

Issued 19/06/2025

Expires 19/06/2030

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Beta Valve System Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Beta Valve System Ltd
Park House Business Centre
Desborough Park Road
High Wycombe
Bucks
HP12 3DJ
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2506710

The following products belong to this certificate

PRODUCT DESCRIPTION '1175B' range of servo-controlled normally closed (NC), normally open (NO) or latching solenoid valves. For use with copper tube manufactured to EN1057 or John Guest Speedfit barrier pipe manufactured to BS7291 part 3. ATS3 – Without Production Surveillance.
MODEL(S) 1175BC (normally closed). 1175BA (normally open). 1175BB (latching).
SIZE: 15mm pushfit.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.
MARKING RPE logo on body and date of manufacture.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES Opacity cannot be guaranteed.

Extra Notes